# South Gloucestershire Council's Room Size and Amenity Standards for Licensable Houses in Multiple Occupation (HMOs) under Part 2 of the Housing Act 2004 (November 2018)

#### Contents:

- 1. Amenity standards for HMOs or parts of HMOs either occupied by a socially interactive group (shared houses or shared flats normally subject to a joint tenancy) or by individual households living independently who either share facilities (some shared houses and bedsits) or have exclusive use of facilities (self-contained flats).
- 2. Room size standards for properties occupied as above. Please contact us for specific standards for HMOs where some board is provided these properties are referred to as 'hostels'.

#### Notes:

- 3. The amenity standards include those prescribed by The Licensing and Management of Houses in Multiple Occupation and Other (Miscellaneous Provisions) (England) Regulations 2006 (SI 2006 No. 373).
- 4. The additional amenity standards indicate how the WoE local authorities will regard how the 'Tests as to suitability for multiple occupation' can be met under Section 65 Housing Act 2004.
- 5. The room size standards indicate how the WoE local authorities will decide on the maximum occupation of the property under Section 64 Housing Act 2004; this is known as the 'permitted number'.
- 6. The above standards need not necessarily be met on the date a licence becomes operative. Where this is not the case, a schedule of works will be issued and, in some circumstances, a licence will be issued with conditions requiring compliance with the standards within a required time period.
- 7. The standards do not apply to non-licensable HMOs but can be used as a guide. Instead, the Housing, Health & Safety Rating System under Part 1 of the Housing Act 2004 will be used to assess the suitability of amenity standards and living space.
- 8. All licensed HMOs will be subject to an assessment using the Housing Health and Safety Rating System (HHSRS) under Part 1 Housing Act 2004 and the applicable HMO Management Regulations. As a result, it is possible that there will be additional requirements to be met.

#### Application:

- 9. Where reasonably practicable all HMO licensing standards must be complied with. However, every case must be considered on its own merits as Councils cannot apply a blanket set of standards for all HMOs in its district taking no account of the individual circumstances of the HMO in question. This will particularly be in respect of those standards that are not prescribed by legislation.
- 10. It is recommended that the Council is consulted prior to undertaking works.

HMO Licensing Standards						
for facilities provided for shared and exclusive use  Personal washing and toilet facilities						
Location, size and condition	General	All facilities should be located in rooms of an adequate size and layout within 2 floors of any bedroom and accessible from communal areas unless provided as en-suite facilities for the exclusive use of that occupant. Facilities should be inside the building.  All baths or showers, toilets and wash hand basins should be of an adequate size and be provided with an adequate water supply, necessary fittings, drainage and be in a satisfactory condition to enable thorough cleaning. Constant hot water at a suitable temperature to be provided to baths / showers and wash basins. Baths or showers and wash hand basins should be properly sealed into wall surfaces and have 300mm of tiled splashback (or equivalent). Bathrooms and toilet compartments should be of an adequate size and layout.				
Wash hand basins	Shared use	To be provided either within each individual unit of accommodation or within each share bathroom and compartment containing a toilet (see table below).  Within each room and compartment containing a toilet.				
	Exclusive use	Within each room and compartment containing a toilet.				
Baths or showers and toilets	Shared use	Where there are four or fewer occupiers sharing there must be at least one fixed bath or shower and a toilet (which may be situated in the bathroom). Where there are five or more occupiers sharing there must be at least a fixed bath or shower for every 5 occupants (or part of), and at least one toilet separate to the bathroom for every 5 occupants (or part of). A further complete bathroom would be acceptable in place of a separate toilet. If this is not reasonably practical to do this, we will be happy to discuss alternatives with you. See table below as to how this standard can be met.  In hostels where children are accommodated, at least one bath should be provided.				
	Exclusive use	A fixed bath or shower and a toilet.				
Ventilation	General	Bathrooms to have mechanical ventilation to the outside air at a minimum extraction rate of 15 litres/second in addition to any window(s).  Each toilet in a separate compartment is required to have a window equivalent to 1/20 <sup>th</sup> of the floor area or mechanical ventilation to the outside air at a minimum extraction rate of 6 litres/second.  Ventilation should not be obstructed externally.				
Heating	General	A fixed heating appliance in each bath or shower room sufficient to minimise condensation and provide thermal comfort.				
Kitchens						
Location, size and condition	General	If kitchens do not have a suitable dining area this facility must be provided within one floor distant (this may be a living room, bedsit or bedroom of suitable size - see standards for room sizes).  If hostels provide all main meals the kitchen facilities below are to be provided for every 10 occupants and the cooker can be replaced with a microwave. If hostels have a				

		commercial kitchen where access is not available at all times, a separate kitchen must be provided to the standards below.			
		Kitchens must have a safe and efficient layout and be of a suitable size - see standards for room sizes.			
		All facilities and equipment must be fit for purpose.			
Sinks	Shared use	A sink with constant hot and cold water, a draining board and tiled splash back to be provided for up to 5 occupants (a dishwasher will be acceptable as a second sink) or within an individual unit of accommodation. For 6 occupants a 1 ½ bowl sink will be acceptable.			
	Exclusive use	A sink with constant hot and cold water, tiled splash back and a draining board.			
Cookers Shared use		A cooker with a 4 ring hob, oven and a grill for every 5 occupants or within an individual unit of accommodation. A large microwave with oven and grill will be acceptable as a second cooker.			
	Exclusive	A cooker with a 4 ring hob, oven and grill.			
	use	A cooker with a 4 ring hob, oven and grill or a 2 ring hob, oven and grill together (positioned so that hobs are at worktop level) with a microwave will be acceptable in accommodation occupied by a single person.			
Electrical Sockets	General	Four suitably positioned electric sockets are required plus one per major appliance (i.e. a cooker, microwave, refrigerator/freezer, washing machine etc.).			
Worktop	Shared use	Fixed worktop(s) with a smooth impervious surface for food preparation, minimum size 500mm x 1000mm for up to 5 occupants or within an individual unit of accommodation.			
	Exclusive use	Fixed worktop(s) with a smooth impervious surface for food preparation, minimum size 500mm x 1000mm.			
Storage	Shared use	A 0.3m3 dry goods storage cupboard other than a sink base unit per occupier either in each occupant's room or in a shared kitchen.			
	Exclusive use	A 0.6m3 dry goods storage cupboard other than a sink base unit.			
Refrigerators Shared use		Two worktop height refrigerators with freezer compartments or 1 worktop height fridge and 1 worktop height freezer per 5 occupiers, or a worktop height refrigerator with a freezer compartment within each individual unit of accommodation.			
	Exclusive use	A worktop height refrigerator with a freezer compartment.			
Refuse	General	Suitable and sufficient provision for household waste and recycling disposal both within the unit of accommodation and outside.			
Ventilation	Shared use	Mechanical ventilation to the outside air at a minimum extraction rate of 60 litres/second or 30 litres/second if the fan is sited within 300mm of the centre of the hob. This is in addition to any windows.			
Heating					
Fixed heating	General	A fixed and efficient heating appliance(s) capable of maintaining a temperature of 21°C with an outside temp of -1°C in each unit of living accommodation (electrical appliances			

		must have a dedicated socket). Heating should be available at all times and be under the control of the occupier.				
Access						
All facilities are to	be availa	able at all times and should be internally accessed from all bedrooms and bedsitting rooms.				
Definitions						
		ere one or more basic amenities (personal washing, toilet or kitchen) are shared by two or re households.				
Exclusive use	Wh	ere a basic amenity is provided for the use of a single household.				
Bedsit accommodation		Accommodation occupied by person(s) living independently of others in the HMO. Individual bedsits will provide the facilities for living, sleeping and cooking/eating.				
Single household		Person(s) of the same family group, this includes an individual living on their own. An ndividual living in a group is also regarded as a single household.				
Family/household		cludes husband, wife, partner, child, stepchild, step parent, grandchild, grandparent, brother, ster, half-brother, half-sister, aunt, uncle, niece, cousin, foster child.				
accommodation		t of the HMO occupied by a single household, this includes bedrooms in shared houses or s, bedsitting rooms, self-contained flats (all basic amenities provided for exclusive use of thousehold).				
Hostel		Where board is provided as part of the occupation and it constitutes a persons only or main place of residence. Hostel includes bed and breakfast and hotel accommodation used by persons as their only and main residence which is a house in multiple occupation.				

### Table to explain how the standards for baths/showers and toilets can be met

No. of persons sharing	Total no. of baths/showers and toilets* required	No. of toilets* that need to be separate	Or, no. of complete bathrooms accepted (bath/shwr toilet and whb)		
1	1	0	-		
2	1	0	-		
3	1	0	-		
4	1	0	-		
5	1	1**	2		
6	2	1**	3		
7	2	1**	3		
8	2	1	3		
9	2	1	3		
10	2	1	3		
11	3	1	4		
12	3	1	4		
13	3	1	4		
14	3	1	4		
15	3	1	4		
20	4	2	6 or (5 + 1 separate toilet)		

<sup>\*</sup> excluding outside toilets, a wash hand basin (whb) is to be provided within each room or compartment containing a toilet.

\*\*only if reasonably practicable to provide i.e. there must be a suitable room (includes creating an en suite facility within a suitably sized bedroom) or space to install a toilet (with whb) from which a connection can be made into the foul drainage system without the need for a pumped system; alternatively, a bathroom could be partitioned off without the need to make an opening in a structural wall, the resultant layout should leave reasonable space for changing, drying etc.

#### Licensable HMO minimum room sizes

Please note when calculating the size of a bedroom, any area of the room in which the distance between the lowest part of the floor and the ceiling is less than 1.5m cannot be counted towards the minimum room size.

## Accommodation with facilities shared by occupiers

These standards apply where there is sharing of some or all facilities i.e. HMOs where:

- occupiers live independently of others e.g. single room lettings or bedsit accommodation (kitchen facilities within own room);
- occupiers forming a group e.g. students, professional persons and others who interact socially.

### Room Sizes where the Room is for the Sole Use of Occupier(s)

	Number of Persons			
	1 person under	1	2	
	the age of 10			
Kitchen	N/A	4 m <sup>2</sup>	5 m <sup>2</sup>	
Combined kitchen and living room	N/A	11 m <sup>2</sup>	15 m <sup>2</sup>	
Bedroom	4.64 m <sup>2</sup>	6.51 m <sup>2</sup>	10.22 m <sup>2</sup>	
Combined bed and living room	N/A	9 m <sup>2</sup>	14 m <sup>2</sup>	
Combined bedroom, living room & kitchen	N/A	13 m <sup>2</sup>	19 m²	

## Room Sizes where the Room is Shared by Occupier(s)

	Number of Persons							
	1-3	4	5	6	7	8	9	10 <sup>i</sup>
Kitchen <sup>ii</sup>	5 m <sup>2</sup>	6 m <sup>2</sup>	7 m <sup>2</sup>	9 m <sup>2</sup>	10 m <sup>2</sup>	10 m <sup>2</sup>	11 m <sup>2</sup>	11 m <sup>2</sup>
Total communal living space <sup>iii</sup>	13.5 m <sup>2</sup>	17 m <sup>2</sup>	18 m <sup>2</sup>	20 m <sup>2</sup>	22 m <sup>2</sup>	24 m <sup>2</sup>	26 m <sup>2</sup>	27.5 m <sup>2</sup>

For more than 10 persons, please contact the Private Sector Housing Team to discuss proposed room sizes

Independent living only

Occupiers forming a group (includes kitchen, dining rooms and living rooms – the kitchen must be at least the minimum size specified above)